

Government of the People's Republic of Bangladesh
National Board of Revenue
Segunbagicha, Dhaka
www.nbr.gov.bd

File No:

Date: /03/2020

This is notifying to all concern that the following Amendments are made to the Tender Ref No. 08.01.0000.091.53.001.19, Package: 02: Supply, Installation, Commissioning of the Data Center at Dhaka Custom House with 3 years IT Support Service., Published on : 26/02/2020.

Amendments on Tender Last Selling Date, Closing Date and Time and Opening Date and Time:

Tender Information			<i>Existing As</i>			<i>Changed As</i>		
#	Package No	Package Name	Last Selling Date	Closing Date and Time	Opening Date and Time	Last Selling Date	Closing Date and Time	Opening Date and Time
1	Package-02	Supply, Installation, Commissioning of the Data Center at Dhaka Custom House with 3 years IT Support Service.	23/03/2020	24/3/2020 12:00 PM	24/3/2020 12:30 PM	29/03/2020	30/3/2020 02:00 PM	30/3/2020 02:30 PM

Amendments on Section-2: Tender Data Sheet

#	Section	Page	Existing Information	Amendment
1	ITT 14.1(c)	29	The minimum supply value of goods and related services of the bidder/tenderer under a single Contract in the last 05 years is at least 3 (three) crores.	The minimum supply value of goods and related services of the bidder/tenderer under a single Contract in the last 05 years is at least 2 (two) crores.

Amendments on Section-7: Tender Specifications

#	Section	Page	Existing Information	Amendment
1	7	111	Precision Cooling for NBR present Server Room Brand: Vertiv/Stulz/Bluebox	Precision Cooling for NBR present Server Room Brand: Vertiv/Stulz/Bluebox/Uniflair By schneider
3.23 Datacenter Infrastructure Management and Control				
2	7	112	Datacenter Infrastructure Management and Control Country of Manufacture: USA/EU	Country of Origin & Manufacture: NORTH AMERICA/EUROPE/AUSTRALIA CONTINENT
				DCIM license Full license required for 15 Racks
				Sensors Vibration Sensors, Temperature Sensors, Temperature & Humidity sensors (minimum 20 nos or more) as per requirement of data center to comply TIER III data center
				Water Leak Detectors Vendor to proposed water leak Detection System to cover data center server & power room
4.5.3 Datacenter Infrastructure Management and Control				
2	7	211	Datacenter Infrastructure Management and Control Country of Manufacture: USA/EU	Country of Origin & Manufacture: NORTH AMERICA/EUROPE/AUSTRALIA CONTINENT
				DCIM license Full license required for 15 Racks

				Sensors Vibration Sensors, Temperature Sensors, Temperature & Humidity sensors (minimum 20 nos or more) as per requirement of data center to comply TIER III data center
				Water Leak Detectors Vendor to proposed water leak Detection System to cover data center server & power room
4.3 Raised Floor for Data Centre				
	7		Panels will be insulated against heat and noise transfer. Panels will be 600 x 600mm x 35 mm height fully interchangeable with each other within the range of a specified layout	Panels will be insulated against heat and noise transfer. Panels will be 600 x 600mm x 30 mm height fully interchangeable with each other within the range of a specified layout
		145		
	7		Country of Origin USA/EU	Country of Origin NORTH AMERICA/EUROPE/AUSTRALIA CONTINENT
		145		
4.4.1 Specification of Online UPS				
	7		Module: Minimum-25 KVA / kw per module	Module: Minimum-20 KVA / KW per module
		150		

(Syed Golam Kibria)
Member (Customs: Policy & ICT)
National Board of Revenue
Segunbagicha, Dhaka.